

Confirmation

LEED

On 6 April 2018, Eurofins Product Testing A/S received a sample of resin based flooring with the product name:

Corques Liquid Lino (CLL)

supplied by

Duracryl International

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, CDPH 01350, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2018-00139701_H_EN_06_rev1 and 392-2018-00144201_XG_EN_Rev2_06).

The test results of the tested coating indicate that the product qualifies for LEED v4 specifications on VOC emissions and/or VOC content by complying with:


VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of SCAQMD rule 1168 (2005)

18 June 2018



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.